


衛生福利部食品藥物管理署管制藥品製藥工廠
材料規格

文件名稱	1 毫升茶色玻璃安瓿			頁 碼	第 3 頁 共 6 頁
文件編號	P101	版次	10	生效日期	102.9.10

1. 材質：注射劑玻璃容器依最新 USP 規定為 Type I，硼矽質硬質玻璃容器 (High resistant, borosilicate glass)，其玻璃管厚度為 $0.45 \pm 0.03 \text{ mm}$ ，由廠商提供材質證明。
2. 包裝：每 400~800 支盒裝，盒具雙面開口，寬度 26 公分，瓶口向上，外箱應標明品名、數量、批號或製造日期及廠名，箱內外應清潔，不得有異物污染。
3. 外觀：

	項 目	樣本數	AQL	Ac	Re
1	本品為茶褐色玻璃安瓿，以安瓿用玻璃管加工製成之直筒型，外型平滑完整，瓶口鍛燒平整呈圓形，色澤均勻，不得有深淺不一。	125	1.5	5	6
2	本品不得有底歪頸斜，中心線不正，影響藥液充填作業情形。一次取 10 支安瓿使站立排列成直線，旋轉不同角度檢視，挑出瓶身異常傾斜者，測量瓶身中心線（瓶口圓心至瓶底圓心）之傾斜角度，不得大於 5° 。	125	0.65	2	3
3	本品不得有肉眼可查覺之雜物、絲紋、氣泡及裂痕。	125	1.5	5	6
4	本品不得有直徑大於 1mm 之污點。	125	0.25	1	2
5	本品為 One-point 預割產品，不得有無預割之情形。	125	0.65	2	3
6	本品為 One-point 預割產品，有預割但無標示，或位置標示不當。	125	1.5	5	6
7	本品不得混雜任何他廠已印字之安瓿。	1250	0.010	0	1

4. 重量及尺寸單位：重量為 gm，尺寸為 mm（廠商需附每生產批之品質管制紀錄）。
口徑 d4 及頸壁厚 S2 之量測點為安瓿開口下方 15 mm 處（約熔封點）。



項 目	代號	範 圍	樣本數
重量	W	1.34~1.64	32
胴徑	d1	9.75~10.30	32
絞徑	d2	5.3~6.1	32
玉徑	d3	6.0~7.0	32
口徑	d4	5.0~6.0	32
內徑	d5	4.0~5.3	32
全長	h1	63~66	32
胴高	h4	27~29	32
管壁厚	S1	0.42~0.48	10
頸壁厚	S2	0.25~0.40	10

標準書
發 放 章

102.09.12

高郁琪

衛生福利部食品藥物管理署管制藥品製藥工廠
材料規格

文件名稱	1 毫升茶色玻璃安瓿			頁 碼	第 4 頁 共 6 頁
文件編號	P101	版次	10	生效日期	102.9.10

註：尺寸及重量如不合格數 ≥ 2 支即判不合格。如不合格數為 1 支，則加倍取樣，兩次量測如不合格數 ≥ 3 支即判不合格。

5. 折斷面平整度測試：折斷時安瓿瓶身不得破碎。(樣本數 125, $Ac=0$, $Re=1$)

6. **CHEMICAL RESISTANCE**：詳見 2012 USP 35《660》CONTAINERS—GLASS

6.1 Powdered Glass Test：安瓿清潔乾燥後，將之折斷，棄去有預割標示點之上半截，保留下半截進行本試驗。

Table 2. Test Limits for Powdered Glass Test

Type	General Description ^a	Type of Test	Limits	
			Size, ^b mL	mL of 0.020 N Acid
I	Highly resistant, borosilicate glass	Powdered Glass	All	1.0
III	Soda-lime glass	Powdered Glass	All	8.5

^a The description applies to containers of this type of glass usually available.
^b Size indicates the overflow capacity of the container.

6.2 Surface Glass Test

Table 3. Volume of Test Liquid and Number of Titrations

Filling Volume (mL)	Volume of Test Liquid for One Titration (mL)	Number of Titrations
Up to 3	25.0	1
Above 3 and up to 30	50.0	2
Above 30 and up to 100	100.0	2
Above 100	100.0	3



衛生福利部食品藥物管理署管制藥品製藥工廠
材料規格

文件名稱	1 毫升茶色玻璃安瓿			頁 碼	第 5 頁 共 6 頁
文件編號	P101	版次	10	生效日期	102. 9. 10

Table 4. Test Limits for Surface Glass Test

	Maximum Volume of 0.01 M HCl per 100 mL of Test Liquid (mL)	
Filling Volume (mL)	Types I and II	Type III
Up to 1	2.0	20.0
Above 1 and Up to 2	1.8	17.6
Above 2 and Up to 5	1.3	13.2
Above 5 and Up to 10	1.0	10.2
Above 10 and Up to 20	0.80	8.1
Above 20 and Up to 50	0.60	6.1
Above 50 and Up to 100	0.50	4.8
Above 100 and Up to 200	0.40	3.8
Above 200 and Up to 500	0.30	2.9
Above 500	0.20	2.2

7. 砷(Arsenic)：限量 0.1 ppm。

檢品試液取自 Surface Glass Test。

測定法：以原子吸收光譜儀測定之。



衛生福利部食品藥物管理署管制藥品製藥工廠
材料規格

文件名稱	1 毫升茶色玻璃安瓿			頁 碼	第 6 頁 共 6 頁
文件編號	P101	版次	10	生效日期	102. 9. 10

8. LIGHT TRANSMISSION TEST：詳見 2012 USP 35〈671〉

CONTAINERS—PERFORMANCE TESTING

Table 2. Limits for Plastic Classes I–VI and

Glass Types I, II, and III

Nominal Size (in mL)	Maximum Percentage of Light Transmission at Any Wavelength between 290 and 450 nm	
	Flame-sealed Containers	Closure-sealed Containers
1	50	25
2	45	20
5	40	15
10	35	13
20	30	12
50	15	10

9. 附件：

(1)2012 USP 35 版 (660) Containers-Glass。

(2)2012 USP 35 版 (671) Containers-Performance Testing。



《 660 》 CONTAINERS—GLASS

Glass containers for pharmaceutical use are intended to come into direct contact with pharmaceutical preparations. Glass used for pharmaceutical containers is either a borosilicate (neutral) glass or a soda-lime glass. Borosilicate glass contains a significant amount of boric oxide, aluminum oxide, and alkali and/or alkaline earth oxides.

Borosilicate glass has a high hydrolytic resistance due to the chemical composition of the glass itself; it is classified as Type I glass. Soda-lime glass is a silica glass containing alkali metal oxides. Soda-lime glass has a moderate hydrolytic resistance due to the chemical composition of the glass itself; it is classified as Type III glass. The inner surface of glass containers may be treated, for example, to improve hydrolytic resistance. The treatment of Type III soda-lime glass containers will raise their hydrolytic resistance from a moderate to a high level, changing the classification of the glass to Type II.

The outer surface of glass containers may be treated to reduce friction or for protection against abrasion or breakage. The treatment of the outer surface does not come into contact with the inner surface of the container. Glass may be colored to provide protection from light or may have a coating applied to the outer surface. Such containers will meet the requirements for *Light Transmission* under Containers—Performance Testing 《 671 》. A clear and colorless or a translucent container that is made light-resistant by means of an opaque enclosure (see *Light-Resistant Container in Preservation, Packaging, Storage, and Labeling* under the General Notices) is exempt from the requirements for *Light Transmission*.

The quality of glass containers is defined by measuring their resistance to chemical attack. In addition, Type I containers for aqueous parenteral preparations are tested for arsenic release, and colored glass containers are tested for light transmission.

CHEMICAL RESISTANCE

The following tests are designed to determine the resistance to water attack of new (not previously used) glass containers. The degree of attack is determined by the amount of alkali released from the glass under the influence of the attacking medium under the conditions specified. This quantity of alkali is extremely small in the case of the more resistant glasses, thus calling for particular attention to all details of the tests and the use of apparatus of high quality and precision. The tests should be conducted in an area relatively free from fumes and excessive dust.

Glass Types— Glass containers suitable for packaging Pharmacopeial preparations may be classified as in Table 1 on the basis of the tests set forth in this section. Containers of Type I borosilicate glass are generally used for preparations that are intended for parenteral administration. Containers of Type I glass, or of Type II glass (i.e., soda-lime

glass that is suitably dealkalized) are usually used for packaging acidic and neutral parenteral preparations. Type I glass containers, or Type II glass containers (where stability data demonstrate their suitability), are used for alkaline parenteral preparations. Type III soda-lime glass containers usually are not used for parenteral preparations, except where suitable stability test data indicate that Type III glass is satisfactory for the parenteral preparations that are packaged therein.

Table 1. Glass Types

Type	General Description	Type of Test
I	Highly resistant, borosilicate glass	<i>Powdered Glass</i>
II	Treated soda-lime glass	<i>Water Attack</i>
III	Soda-lime glass	<i>Powdered Glass</i>

Apparatus—

Autoclave— For these tests, use an autoclave capable of maintaining a temperature of $121 \pm 2.0^{\circ}$, equipped with a thermometer, a pressure gauge, a vent cock, and a rack adequate to accommodate at least 12 test containers above the water level.

Mortar and Pestle— Use a hardened-steel mortar and pestle, made according to the specifications in *Figure 1*.




Figure 1. Mortar and Pestle for Pulverizing Glass¹

Other Equipment— Also required are 20.3-cm (8-inch) sieves made of stainless steel, including the Nos. 20, 40, and 50 sieves, along with the pan and cover (see *Sizes of Standard Sieve Series in Range of Interest* under *Particle Size Distribution Estimation by Analytical Sieving* (786)); 250-mL conical flasks made of resistant glass aged as specified; a 900-g (2-lb) hammer; a permanent magnet; a desiccator; and an adequate volumetric apparatus.

Reagents—

High-Purity Water— The water used in these tests has a conductivity at 25°, as measured in an in-line cell just prior to dispensing, of not greater than 0.15 µS per cm

(6.67 Megohm-cm). There must also be an assurance that this water is not contaminated by copper or its products (e.g., copper pipes, stills, or receivers). The water may be prepared by passing distilled water through a deionizer cartridge packed with a mixed bed of nuclear-grade resin, then through a cellulose ester membrane having openings not exceeding $0.45\ \mu\text{m}$.² Do not use copper tubing. Flush the discharge lines before water is dispensed into test vessels. When the low conductivity specification can no longer be met, replace the deionizer cartridge.

Carbon Dioxide-Free Water— This is Purified Water that has been boiled vigorously for 5 minutes or more and allowed to cool while protected from absorption of carbon dioxide from the atmosphere, or Purified Water that has a resistivity of not less than 18 Mohm-cm.

Methyl Red Solution (Powdered Glass Test and Water Attack at 121°)— Dissolve 24 mg of methyl red sodium in Purified Water to make 100 mL. If necessary, neutralize the solution with 0.02 N sodium hydroxide, or acidify it with 0.02 N sulfuric acid so that the titration of 100 mL of *High-Purity Water*, containing 5 drops of indicator, does not require more than 0.020 mL of 0.020 N sodium hydroxide to effect the color change of the indicator, which should occur at a pH of 5.6.

Methyl Red Solution (Surface Glass Test)— Dissolve 50 mg of methyl red solution in 1.86 mL of 0.1 M sodium hydroxide and 50 mL of ethanol (96%) and dilute to 100 mL with Purified Water. To test for sensitivity, add 100 mL of *Carbon Dioxide-Free Water* and 0.05 mL of 0.02 M hydrochloric acid to 0.1 mL of the methyl red solution (the solution should be red). Not more than 0.1 mL of 0.02 M sodium hydroxide is required to change the color to yellow. Color change: pH 4.4 (red) to pH 6.0 (yellow).

Powdered Glass Test

Rinse thoroughly with Purified Water six or more containers selected at random, and dry them with a current of clean, dry air. Crush the containers into fragments about 25 mm in size, divide about 100 g of the coarsely crushed glass into three approximately equal portions, and place one of the portions in the special mortar. With the pestle in place, crush the glass further by striking 3 or 4 blows with the hammer. Nest the sieves, and empty the mortar into the No. 20 sieve. Repeat the operation on each of the two remaining portions of glass, emptying the mortar each time into the No. 20 sieve. Shake the sieves for a short time, then remove the glass from the Nos. 20 and 40 sieves, and again crush and sieve as before. Repeat again this crushing and sieving operation. Empty the receiving pan, reassemble the nest of sieves, and shake by mechanical means for 5 minutes or by hand for an equivalent length of time. Transfer the portion retained on the No. 50 sieve, which should weigh in excess of 10 g, to a closed container, and store in a desiccator until used for the test.

Spread the specimen on a piece of glazed paper, and pass a magnet through it to remove

particles of iron that may be introduced during the crushing. Transfer the specimen to a 250-mL conical flask of resistant glass, and wash it with six 30-mL portions of acetone, swirling each time for about 30 seconds, and carefully decanting the acetone. After washing, the specimen should be free from agglomerations of glass powder, and the surface of the grains should be practically free from adhering fine particles. Dry the flask and contents for 20 minutes at 140°, transfer the grains to a weighing bottle, and cool in a desiccator. Use the test specimen within 48 hours after drying.

Procedure— Transfer 10.00 g of the prepared specimen, accurately weighed, to a 250-mL conical flask that has been digested (aged) previously with *High-Purity Water* in a bath at 90° for at least 24 hours or at 121° for 1 hour. Add 50.0 mL of *High-Purity Water* to this flask and to one similarly prepared to provide a blank. Cap all flasks with borosilicate glass beakers that previously have been treated as described for the flasks and that are of such size that the bottoms of the beakers fit snugly down on the top rims of the containers. Place the containers in the autoclave, and close it securely, leaving the vent cock open. Heat until steam issues vigorously from the vent cock, and continue heating for 10 minutes. Close the vent cock, and adjust the temperature to 121°, taking 19 to 23 minutes to reach the desired temperature. Hold the temperature at $121 \pm 2.0^\circ$ for 30 minutes, counting from the time this temperature is reached. Reduce the heat so that the autoclave cools and comes to atmospheric pressure in 38 to 46 minutes, being vented as necessary to prevent the formation of a vacuum. Cool the flask at once in running water, decant the water from the flask into a suitably cleansed vessel, and wash the residual powdered glass with four 15-mL portions of *High-Purity Water*, adding the decanted washings to the main portion. Add 5 drops of *Methyl Red Solution*, and titrate immediately with 0.020 N sulfuric acid. If the volume of titrating solution is expected to be less than 10 mL, use a microburet. Record the volume of 0.020 N sulfuric acid used to neutralize the extract from 10 g of the prepared specimen of glass, corrected for a blank. The volume does not exceed that indicated in *Table 2* for the type of glass concerned.

Table 2. Test Limits for Powdered Glass Test

Type	General Description ^a	Type of Test	Limits	
			Size, ^b mL	mL of 0.020 N Acid
I	Highly resistant, borosilicate glass	<i>Powdered Glass</i>	All	1.0
III	Soda-lime glass	<i>Powdered Glass</i>	All	8.5
^a The description applies to containers of this type of glass usually available.				
^b Size indicates the overflow capacity of the container.				

Surface Glass Test

Determination of the Filling Volume— The filling volume is the volume to be filled with

Purified Water in the container for the purpose of the test. For vials and bottles the filling volume is 90% of the brimful capacity. For ampules it is the volume up to the height of the shoulder.

Vials and Bottle— Select, at random, 6 containers from the sample lot, or 3 if their capacity exceeds 100 mL, and remove any dirt or debris. Weigh the empty containers with an accuracy of 0.1 g. Place the containers on a horizontal surface, and fill them with Purified Water to about the rim edge, avoiding overflow and introduction of air bubbles. Adjust the liquid levels to the brimful line. Weigh the filled containers to obtain the mass of the water, expressed to 2 decimal places, for containers having a nominal volume less or equal to 30 mL, and expressed to 1 decimal place for containers having a nominal volume greater than 30 mL. Calculate the mean value of the brimful capacity in mL, and multiply it by 0.9. This volume, expressed to 1 decimal place, is the filling volume for the particular container lot.

Ampules— Place at least 6 dry ampules on a flat, horizontal surface, and fill them with Purified Water from a buret until the water reaches point A, where the body of the ampule decreases to the shoulder of the ampule (see Figure 2). Read the capacities, expressed to 2 decimal places, and calculate the mean value. This volume, expressed to 1 decimal place, is the filling volume for the particular ampule lot. The filling volume may also be determined by weighing.




Figure 2. Filling Volumes of Ampules (up to point A)

Test— The determination is carried out on unused containers. The volumes of the test liquid necessary for the final determination are indicated in *Table 3*.

Table 3. Volume of Test Liquid and Number of Titrations

Filling Volume (mL)	Volume of Test Liquid for One Titration (mL)	Number of Titrations
Up to 3	25.0	1
Above 3 and up to 30	50.0	2
Above 30 and up to 100	100.0	2
Above 100	100.0	3

Cleaning— Remove any debris or dust. Shortly before the test, rinse each container carefully at least twice with *Purified Water*, and allow to stand. Immediately before testing, empty the containers, rinse once with *Purified Water*, then with *Carbon Dioxide-Free Water* and allow to drain. Complete the cleaning procedure from the first rinsing in not less than 20 minutes and not more than 25 minutes. Heat closed ampules in a water bath or in an air-oven at about 50° for approximately 2 minutes before opening. Do not rinse before testing.

Filling and Heating— The containers are filled with *Carbon Dioxide-Free Water* up to the filling volume. Containers in the form of cartridges or prefilled syringes are closed in a suitable manner with material that does not interfere with the test. Each container, including ampules, shall be loosely capped with an inert material such as a dish of neutral glass or aluminum foil previously rinsed with *Purified Water*. Place the containers on the tray of the autoclave.

Place the tray in the autoclave containing a quantity of water such that the tray remains clear of the water. Close the autoclave, and carry out the following operations:

1. heat the autoclave to 100° and allow the steam to issue from the vent cock for 10 minutes;
2. close the vent cock and raise the temperature from 100° to 121° at a rate of 1° per minute;
3. maintain the temperature at $121 \pm 1^\circ$ for 60 ± 1 minutes;
4. lower the temperature from 121° to 100° at a rate of 0.5° per minute, venting to prevent a vacuum;
5. do not open the autoclave before it has cooled down to 95°;
6. remove the containers from the autoclave using normal precautions, place them in a water bath at 80°, and run cold tap water, taking care that the water does not contact the loose foil caps to avoid contamination of the extraction solution;
7. cooling time does not exceed 30 minutes.

The extraction solutions are analyzed by titration according to the method described

below.

Method— Carry out the titration within 1 hour of removal of the containers from the autoclave.

Combine the liquids obtained from the containers, and mix. Introduce the prescribed volume indicated in *Table 3* into a conical flask. Place the same volume of *Carbon Dioxide-Free Water* into a second similar flask as a blank. Add 0.05 mL of *Methyl Red Solution* to each flask for each 25 mL of liquid. Titrate the blank with 0.01 M hydrochloric acid. Titrate the test liquid with the same acid until the color of the resulting solution is the same as that obtained for the blank. Subtract the value found for the blank titration from that found for the test liquid, and express the results in mL of 0.01 M hydrochloric acid per 100 mL. Express titration values of less than 1.0 mL to 2 decimal places and titration values of more than or equal to 1.0 mL to 1 decimal place.

Limits— The results, or the average of the results if more than one titration is performed, are not greater than the values stated in *Table 4*.

Table 4. Test Limits for Surface Glass Test

	Maximum Volume of 0.01 M HCl per 100 mL of Test Liquid (mL)	
Filling Volume (mL)	Types I and II	Type III
Up to 1	2.0	20.0
Above 1 and Up to 2	1.8	17.6
Above 2 and Up to 5	1.3	13.2
Above 5 and Up to 10	1.0	10.2
Above 10 and Up to 20	0.80	8.1
Above 20 and Up to 50	0.60	6.1
Above 50 and Up to 100	0.50	4.8
Above 100 and Up to 200	0.40	3.8
Above 200 and Up to 500	0.30	2.9
Above 500	0.20	2.2

Water Attack at 121°

Option— The *Water Attack at 121°* test can be used to qualify Type II glass. Rinse thoroughly 3 or more containers, selected at random, twice with *High-Purity Water*.

Procedure— Fill each container to 90% of its overflow capacity with *High-Purity Water*, and proceed as directed for *Procedure* under *Powdered Glass Test*, beginning with “Cap all flasks,” except that the time of autoclaving shall be 60 minutes instead of 30 minutes, and ending with “to prevent the formation of a vacuum.” Empty the contents from 1 or more containers into a 100-mL graduated cylinder, combining, in the case of smaller

containers, the contents of several containers to obtain a volume of 100 mL. Place the pooled specimen in a 250-mL conical flask of resistant glass, add 5 drops of *Methyl Red Solution*, and titrate, while warm, with 0.020 N sulfuric acid. Complete the titration within 60 minutes after opening the autoclave. Record the volume of 0.020 N sulfuric acid used, corrected for a blank obtained by titrating 100 mL of *High-Purity Water* at the same temperature and with the same amount of indicator. The volume does not exceed that indicated in *Table 5*.

Table 5. Test Limit for Water Attack at 121^o

Table 1. Test Limit for Water Attack at 121°C				
Type	General Description ^a	Type of Test	Limits	
			Size, ^b mL	mL of 0.020 N Acid
II	Treated soda-lime glass	Water Attack	100 or less	0.7
			Over 100	0.2
^a The description applies to containers of this type of glass usually available.				
^b Size indicates the overflow capacity of the container.				

Arsenic

ARSENIC (211)— Use as the *Test Preparation* 35 mL of the water from one Type I glass container or, in the case of smaller containers, 35 mL of the combined contents of several Type I glass containers, prepared as directed for *Procedure* under *Water Attack at 121^o* or *Surface Glass Test*: the limit is 0.1 µg per g.

¹ A suitable mortar and pestle is available (catalog No. H-17280) from Humboldt Manufacturing Co., 7300 West Agatite Avenue, Norridge, IL, 60706, www.humboldtmg.com

² A suitable nuclear-grade resin mixture of the strong acid cation exchanger in the hydrogen form and the strong base anion exchanger in the hydroxide form, with a one-to-one cation to anion equivalence ratio, is available from the Millipore Corp, 290 Concord Road Billerica, MA, 01821, www.millipore.com; Barnstead International, 2555 Kerper Boulevard Dubuque, IA, 52004, www.barnsteadthermolyne.com; GE Water, 4636 Somerton Road Trevose, PA, 19053, www.gewater.com; Pall, 2200 Northern Boulevard East Hills, NY 11548, www.pall.com; Whatman, 200 Park Avenue Florham Park, NJ, 07932, www.whatman.com; Siemens Water Technologies, 14950 Heathrow Forest Pa, Houston, TX 77032, www.usfilter.com

Auxiliary Information— Please check for your question in the FAQs before contacting USP.

Topic/Question	Contact	Expert Committee
General Chapter	<u>Desmond G. Hunt, Ph.D.</u> Senior Scientific Liaison 1-301-816-8341	(GCPS2010) General Chapters - Packaging Storage and Distribution

Pharmacopeial Forum: Volume No. 37(2)

《671》CONTAINERS—PERFORMANCE TESTING

It is the purpose of this chapter to provide standards for the functional properties of containers and their components used to package regulated articles (pharmaceuticals, biologics, dietary supplements, and devices). Definitions that apply to this chapter are provided in the *Preservation, Packaging, Storage, and Labeling* section of the *General Notices and Requirements*. The tests that follow are provided to determine the moisture permeability and light transmission of containers utilized for regulated articles. The section *Multiple-Unit Containers for Capsules and Tablets* applies to multiple-unit containers. The section *Single-Unit Containers and Unit-Dose Containers for Capsules and Tablets* applies to single-unit and unit-dose containers. The section *Multiple-Unit Containers for Capsules and Tablets (Without Closure)* applies to polyethylene and polypropylene containers that have no closures. The section *Multiple-Unit and Single-Unit Containers for Liquids* applies to multiple-unit and single-unit containers.

A container intended to provide protection from light or offered as a *light-resistant* container meets the requirements for *Light Transmission*, where such protection or resistance is by virtue of the specific properties of the material of which the container is composed, including any coating applied thereto. A clear and colorless or a translucent container that is made *light-resistant* by means of an opaque enclosure (see *General Notices and Requirements*) is exempt from the requirements for *Light Transmission*. As used herein, the term “container” refers to the entire system comprising, usually, the container itself, the liner (if used), the closure in the case of multiple-unit containers, and the lidding and blister in the case of unit-dose containers.

MOISTURE PERMEATION

Multiple-Unit Containers for Capsules and Tablets

Desiccant— Place a quantity of 4- to 8-mesh, anhydrous calcium chloride¹ in a shallow container, taking care to exclude any fine powder, then dry at 110° for 1 hour, and cool in a desiccator.

Procedure— Select 12 containers of a uniform size and type, clean the sealing surfaces with a lint-free cloth, and close and open each container 30 times. Apply the closure firmly and uniformly each time the container is closed. Close screw-capped containers with a torque that is within the range of tightness specified in the accompanying table. Add *Desiccant* to 10 of the containers, designated *test containers*, filling each to within 13 mm of the closure if the container volume is 20 mL or more, or filling each to two-thirds of capacity if the container volume is less than 20 mL. If the interior of the container is more than 63 mm in depth, an inert filler or spacer may be placed in the bottom to minimize the total weight of the container and *Desiccant*; the layer of *Desiccant* in such a container shall be not less than 5 cm in depth. Close each immediately after adding *Desiccant*,

applying the torque designated in the accompanying table when closing screw-capped containers. To each of the remaining 2 containers, designated *controls*, add a sufficient number of glass beads to attain a weight approximately equal to that of each of the *test containers*, and close, applying the torque designated in the accompanying table when closing screw-capped containers. Record the weight of the individual containers so prepared to the nearest 0.1 mg if the container volume is less than 20 mL; to the nearest mg if the container volume is 20 mL or more but less than 200 mL; or to the nearest centigram (10 mg) if the container volume is 200 mL or more; and store at $75 \pm 3\%$ relative humidity and a temperature of $23 \pm 2^\circ$. [NOTE—A saturated system of 35 g of sodium chloride with each 100 mL of water placed in the bottom of a desiccator maintains the specified humidity. Other methods may be employed to maintain these conditions.] After 336 ± 1 hours (14 days), record the weight of the individual containers in the same manner. Completely fill 5 empty containers of the same size and type as the containers under test with water or a noncompressible, free-flowing solid such as well-tamped fine glass beads, to the level indicated by the closure surface when in place. Transfer the contents of each to a graduated cylinder, and determine the average container volume, in mL. Calculate the rate of moisture permeability, in mg per day per L, by the formula:

$$(1000/14V)[(T_F - T_I) - (C_F - C_I)]$$

in which V is the volume, in mL, of the container; $(T_F - T_I)$ is the difference, in mg, between the final and initial weights of each *test container*; and $(C_F - C_I)$ is the difference, in mg, between the average final and average initial weights of the 2 *controls*. For containers used for drugs being dispensed on prescription, the containers so tested are *tight containers* if not more than 1 of the 10 *test containers* exceeds 100 mg per day per L in moisture permeability, and none exceeds 200 mg per day per L. For containers used for drugs being dispensed on prescription, the containers are *well-closed containers* if not more than 1 of the 10 *test containers* exceeds 2000 mg per day per L in moisture permeability, and none exceeds 3000 mg per day per L.

Table 1. Torque Applicable to Screw-Type Container

Closure Diameter ^a (mm)	Suggested Tightness Range with Manually Applied Torque ^b (inch-pounds)
8	5
10	6
13	8
15	5–9
18	7–10
20	8–12
22	9–14
24	10–18

28	12-21
30	13-23
33	15-25
38	17-26
43	17-27
48	19-30
53	21-36
58	23-40
63	25-43
66	26-45
70	28-50
83	32-65
86	40-65
89	40-70
100	45-70
110	45-70
120	55-95
132	60-95

^a The torque designated for the next larger closure diameter is to be applied in testing containers having a closure diameter intermediate to the diameters listed.

^b A suitable apparatus is available from SecurePak, PO Box 1210, Maumee, Ohio 43537-8210. MRA Model with indicators on both the removal and application sides available in the following ranges: 1) 0-25 inch lbs., read in 1-inch lb. increments, 2) 0-50 inch lbs., read in 2-inch lb. increments, and 3) 0-100 inch lbs., read in 5-inch lb. increments. For further detail regarding instructions, reference may be made to "Standard Test Method for Application and Removal Torque of Threaded or Lug-Style Closures" ASTM Method D3198-02, published by the American Society for Testing and Materials, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

Multiple-Unit Containers for Capsules and Tablets (Without Closure)

Polyethylene Container— Fit the containers with impervious seals obtained by heat-sealing the bottles with an aluminum foil-polyethylene laminate or other suitable seal.² Test the containers as specified under *Multiple-Unit Containers for Capsules and Tablets*: the high-density polyethylene containers so tested meet the requirements if the moisture permeability exceeds 10 mg per day per L in not more than 1 of the 10 test containers and exceeds 25 mg per day per L in none of them. The low-density polyethylene containers so tested meet the requirements if the moisture permeability exceeds 20 mg per day per L in not more than 1 of the 10 test containers and exceeds 30 mg per day per L in none of them.

Polypropylene Containers— Fit the containers with impervious seals obtained by heat-sealing the bottles with an aluminum foil-polyethylene laminate or other suitable seal.

Test the containers as described under *Multiple-Unit Containers for Capsules and Tablets*. The containers meet the requirements if the moisture permeability exceeds 15 mg per day per L in not more than 1 of the 10 test containers and exceeds 25 mg per day per L in none of them.

Single-Unit Containers and Unit-Dose Containers for Capsules and Tablets

To permit an informed judgment regarding the suitability of the packaging for a particular type of product, the following procedure and classification scheme are provided for evaluating the moisture-permeation characteristics of single-unit and unit-dose containers. Inasmuch as equipment and operator performance may affect the moisture permeation of a container formed or closed, the moisture-permeation characteristics of the packaging system being utilized shall be determined.

Desiccant— Dry suitable desiccant pellets³ at 110° for 1 hour prior to use. Use pellets weighing approximately 400 mg each and having a diameter of approximately 8 mm.

[NOTE—If necessary due to limited unit-dose container size, pellets weighing less than 400 mg each and having a diameter of less than 8 mm may be used.]

Procedure—

Method I— Seal not fewer than 10 unit-dose containers with 1 pellet in each, and seal 10 additional, empty unit-dose containers to provide the controls, using finger cots or padded forceps to handle the sealed containers. Number the containers, and record the individual weights⁴ to the nearest mg. Weigh the controls as a unit, and divide the total weight by the number of controls to obtain the average. Store all of the containers at 75 ± 3% relative humidity and at a temperature of 23 ± 2°. [NOTE—A saturated system of 35 g of sodium chloride with each 100 mL of water placed in the bottom of a desiccator maintains the specified humidity. Other methods may be employed to maintain these conditions.] After a 24-hour interval, and at each multiple thereof (see *Results*), remove the containers from the chamber, and allow them to equilibrate for 15 to 60 minutes in the weighing area. Again record the weight of the individual containers and the combined controls in the same manner. [NOTE—If any indicating pellets turn pink during this procedure, or if the pellet weight increase exceeds 10%, terminate the test, and regard only earlier determinations as valid.] Return the containers to the humidity chamber. Calculate the rate of moisture permeation, in mg per day, of each container taken by the formula:

$$(1/N)[(W_F - W_I) - (C_F - C_I)]$$

in which N is the number of days expired in the test period (beginning after the initial 24-hour equilibration period); $(W_F - W_I)$ is the difference, in mg, between the final and initial weights of each test container; and $(C_F - C_I)$ is the difference, in mg, between the

average final and average initial weights of the controls, the data being calculated to two significant figures. [NOTE—Where the permeations measured are less than 5 mg per day, and where the controls are observed to reach equilibrium within 7 days, the individual permeations may be determined more accurately by using the 7-day test container and control container weights as W_I and C_I , respectively, in the calculation. In this case, a suitable test interval for *Class A* (see *Results*) would be not less than 28 days following the initial 7-day equilibration period (a total of 35 days).]

Method II— Use this procedure for packs (e.g., punch-out cards) that incorporate a number of separately sealed unit-dose containers or blisters. Seal a sufficient number of packs, such that not fewer than 4 packs and a total of not fewer than 10 unit-dose containers or blisters filled with 1 pellet in each unit are tested. Seal a corresponding number of empty packs, each pack containing the same number of unit-dose containers or blisters as used in the test packs, to provide the controls. Store all of the containers at $75 \pm 3\%$ relative humidity and at a temperature of $23 \pm 2^\circ$. [NOTE—A saturated system of 35 g of sodium chloride with each 100 mL of water placed in the bottom of a desiccator maintains the specified humidity. Other methods may be employed to maintain these conditions.] After 24 hours, and at each multiple thereof (see *Results*), remove the packs from the chamber, and allow them to equilibrate for about 45 minutes. Record the weights of the individual packs, and return them to the chamber. Weigh the control packs as a unit, and divide the total weight by the number of control packs to obtain the average empty pack weight. [NOTE—If any indicating pellets turn pink during the procedure, or if the average pellet weight increase in any pack exceeds 10%, terminate the test, and regard only earlier determinations as valid.] Calculate the average rate of moisture permeation, in mg per day, for each unit-dose container or blister in each pack taken by the formula:

$$(1/NX)[(W_F - W_I) - (C_F - C_I)]$$

in which N is the number of days expired in the test period (beginning after the initial 24-hour equilibration period); X is the number of separately sealed units per pack; $(W_F - W_I)$ is the difference, in mg, between the final and initial weights of each test pack; and $(C_F - C_I)$ is the difference, in mg, between the average final and average initial weights of the control packs, the rates being calculated to two significant figures.

Results— The individual unit-dose containers as tested in *Method I* are designated *Class A* if not more than 1 of 10 containers tested exceeds 0.5 mg per day in moisture permeation rate and none exceeds 1 mg per day; they are designated *Class B* if not more than 1 of 10 containers tested exceeds 5 mg per day and none exceeds 10 mg per day; they are designated *Class C* if not more than 1 of 10 containers tested exceeds 20 mg per day and none exceeds 40 mg per day; and they are designated *Class D* if the containers tested meet none of the moisture permeation rate requirements.

The packs as tested in *Method II* are designated *Class A* if no pack tested exceeds 0.5 mg per day in average blister moisture permeation rate; they are designated *Class B* if no pack tested exceeds 5 mg per day in average blister moisture permeation rate; they are designated *Class C* if no pack tested exceeds 20 mg per day in average blister moisture permeation rate; and they are designated *Class D* if the packs tested meet none of the above average blister moisture permeation rate requirements.

With the use of the *Desiccant* described herein, as stated for *Method I* and *Method II*, after every 24 hours, the test and control containers or packs are weighed; and suitable test intervals for the final weighings, W_F and C_F , are as follows: 24 hours for *Class D*; 48 hours for *Class C*; 7 days for *Class B*; and not less than 28 days for *Class A*.

Multiple-Unit Containers and Unit-Dose Containers for Liquids

The standards and tests provided in this section measure the functional and performance characteristics of bottles used to package aqueous products by measuring the liquid water weight loss as a percent of the contents. This test can also be used to demonstrate performance or functional comparability. [NOTE—Throughout the following procedure, determine the weights of individual container–closure systems (bottle, innerseal if used, and closure) both as tare weights and fill weights, to the nearest 0.1 mg if the bottle capacity is less than 200 mL; to the nearest mg if the bottle capacity is 200 mL or more but less than 1000 mL; or to the nearest centigram (10 mg) if the bottle capacity is 1000 mL or more.]

Procedure— Select 12 bottles of a uniform size and type, and clean the sealing surfaces with a lint-free cloth. Fit each bottle with a seal, closure liner (if applicable), and closure. Number each container–closure system, and record the tare weight. Remove the closures and, using a pipet, fill 10 bottles with water to the fill capacity. Fill 2 containers with glass beads to the same approximate weight of the filled test containers. If using screw closures, apply a torque that is within the range specified in *Table 1*, and store the sealed containers at a temperature of $25 \pm 2^\circ$ and a relative humidity of $40 \pm 2\%$. After 336 ± 1 hours (14 days), record the weight of the individual containers, and calculate the water weight loss rate, in percent per year, for each bottle taken by the formula:

$$\frac{(W_{1i} - W_T) - (W_{14i} - W_T) - (WC_1 - WC_{14})}{(W_{1i} - W_T)} \times \frac{365}{14} = \text{Percent per year}$$

in which W_{1i} is the initial weight of each individual bottle (i); W_T is the tare weight; W_{14i} is the weight of each individual bottle (i) at 14 days; and $(WC_1 - WC_{14})$ is the average weight change of the controls from initial to 14 days.

The containers so tested meet the requirements and are tight containers if the percentage of water weight loss does not exceed 2.5% per year in not more than 1 of the 10 test

containers and does not exceeds 5.0% per year in none of them.

LIGHT TRANSMISSION TEST

Apparatus⁵—Use a spectrophotometer of suitable sensitivity and accuracy, adapted for measuring the amount of light transmitted by either transparent or translucent glass or plastic materials used for pharmaceutical containers. In addition, the spectrophotometer is capable of measuring and recording light transmitted in diffused as well as parallel rays.

Procedure— Select sections to represent the average wall thickness. Cut circular sections from two or more areas of the container and trim them as necessary to give segments of a size convenient for mounting in the spectrophotometer. After cutting, wash and dry each specimen, taking care to avoid scratching the surfaces. If the specimen is too small to cover the opening in the specimen holder, mask the uncovered portion of the opening with opaque paper or masking tape, provided that the length of the specimen is greater than that of the slit in the spectrophotometer. Immediately before mounting in the specimen holder, wipe the specimen with lens tissue. Mount the specimen with the aid of a tacky wax, or by other convenient means, taking care to avoid leaving fingerprints or other marks on the surfaces through which light must pass. Place the section in the spectrophotometer with its cylindrical axis parallel to the plane of the slit and approximately centered with respect to the slit. When properly placed, the light beam is normal to the surface of the section and reflection losses are at a minimum. Continuously measure the transmittance of the section with reference to air in the spectral region of interest with a recording instrument or at intervals of about 20 nm with a manual instrument, in the region of 290 to 450 nm.

Limits— The observed light transmission does not exceed the limits given in Table 2 for containers intended for parenteral use.

**Table 2. Limits for Plastic Classes I–VI and
Glass Types I, II, and III**

	Maximum Percentage of Light Transmission at Any Wavelength between 290 and 450 nm	
Nominal Size (in mL)	Flame-sealed Containers	Closure-sealed Containers
1	50	25
2	45	20
5	40	15
10	35	13
20	30	12
50	15	10

[NOTE—Any container of a size intermediate to those listed above exhibits a transmission

not greater than that of the next larger size container listed in the table. For containers larger than 50 mL, the limits for 50 mL apply.]

The observed light transmission for plastic containers for products intended for oral or topical administration does not exceed 10% at any wavelength in the range from 290 to 450 nm.

¹ Suitable 4- to 8-mesh, anhydrous calcium chloride is available commercially as Item JT1313-1 from VWR International. Consult the VWR International catalog for ordering information or call 1-800-234-9300.

² A suitable laminate for sealing has, as the container layer, polyethylene of not less than 0.025 mm (0.001 inch) and a second layer of aluminum foil of not less than 0.018 mm (0.0007 inch), with additional layers of suitable backing materials. A suitable seal can be obtained also by using glass plates and a sealing wax consisting of 60% of refined amorphous wax and 40% of refined crystalline paraffin wax.

³ Suitable moisture-indicating desiccant pellets are available commercially from sources such as Medical Packaging, Inc., 470 Route 31, Ringoes, NJ 08551-1409 [Telephone 800-257-5282; in NJ, 609-466-8991; FAX 609-466-3775], as Indicating Desiccant Pellets, Item No. TK-1002.

⁴ Accurate comparisons of *Class A* containers may require test periods in excess of 28 days if weighings are performed on a *Class A* prescription balance (see *Prescription Balances and Volumetric Apparatus* (1176)). The use of an analytical balance on which weights can be recorded to 4 or 5 decimal places may permit more precise characterization between containers and/or shorter test periods.

⁵ For further detail regarding apparatus and procedures, reference may be made to the following publications of the American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959: "Standard Method of Test for Haze and Luminous Transmittance of Transparent Plastics," ASTM Method D1003-07; "Tentative Method of Test for Luminous Reflectance, Transmittance and Color of System" ASTM Method E308-06.

Auxiliary Information— Please check for your question in the FAQs before contacting USP.

Topic/Question	Contact	Expert Committee
General Chapter	Desmond G. Hunt, Ph.D. Senior Scientific Liaison 1-301-816-8341	(GCPS2010) General Chapters - Packaging Storage and Distribution

USP35–NF30 Page 282

Pharmacopeial Forum: Volume No. 34(2) Page 337